

Construction Material Laboratory Test Report No: 504518-229

Date: 26-Apr-2018

Page 1 of 2

Client's name / Tên khách hàng

: CB HITECH CO., LTD

Client's address I Địa chỉ

: TẦNG 4, BẢO HIỂM QUÂN ĐỘI MIC, SỐ 8 PHẠM HÙNG,

CÂU GIÂY, HÀ NỘI, VIỆT NAM

The following sample(s) was/were submitted and identified by the client as:

Các thông tin nhận dạng mẫu do khách hàng cung cấp:

Name of sample / Tên mẫu

: JUPITER GREY

Quantity / Số lượng mẫu

01 sample / mẫu

Date of receiving / Ngày nhận mẫu

: 10-Apr-2018

Time of testing / Thời gian thử nghiệm

From / từ 10-Apr-2018 to / đến 26-Apr-2018

Test result / kết quà thử nghiệm

See next page(s) I Xem trang sau



SGS authenticate the photos on original report only I SGS chỉ xác thực các hình ảnh trong báo cáo chính thức

Signed for and on behalf of

SGS Vietnam LTD

Le Long Hai

Construction Lab Manager

Industrial Services

"This document is issued by the Company under its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.vn/en/terms-and-conditions and for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.vn/en/terms-and-conditions/terms-e-document Attention is drawn to the limitations of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested only.

> SGS Vietnam Ltd Office: 198 NguyenThi Minh Khai St District 3 Ho Chi Minh City Vietnam t (84-28) 3935 1920 f (84-28) 3935 1921 www.sgs.com Lab:Lot III/21, 19/5A Street, Industrial Group III, Tan Binh IZ, Tan Phu District, HCMC, Vietnam 🔀 (84-28) 3816 0999 💃 (84-28) 3816 0996



Construction Material Laboratory Test Report No: 504518-229

> Date: 26-Apr-2018 Page 2 of 2

Characteristic Tên chỉ tiêu	Unit Đơn vị	Test methods Phương pháp thử nghiệm	Test result Kết quả thử nghiệm
Bulk specific gravity in dry condition Khối lượng riêng ở trạng thái khô	g/cm³	ASTM C97 - 15	2.74
2. Compressive strength Cường độ nén	MPa	ASTM C170 - 16	144.7
3. Modulus of rupture Môđun phá hủy	MPa	ASTM C99 - 15	18.5
4. Water absorption Độ hút nước	%	ASTM C97 - 15	0.1
5. Flexural strength Cường độ uốn	MPa	ASTM C880 - 15	17.0
6. Flexural modulus of elasticity Môđun đàn hồi uốn	MPa	ASTM C1352 - 15	16840
7. Abrasion resistance ^(*) Độ chịu mài mòn	cm ⁻³	ASTM C1353 - 15a	38.6

Note:

(*) Test conditions / Điều kiện thử nghiệm: 22 ± 3 °C; 50 ± 5 %.

Type of abrasive wheel / Loại bánh mài : H-22.

Load applied to the abrasive wheels (per arm) / Tải trọng áp dụng cho bánh mài : 1000g.

Number of cycles / Số chu kỳ: 1000 cycles.

*** END OF THE REPORT ***

"This document is issued by the Company under its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.vn/en/terms-and-conditions and for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.vn/en/terms-and-conditions/terms-e-document Attention is drawn to the limitations of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested only."